

Mise en service

pour Alimentations Sans Interruption (ASI) monophasées et triphasées

Installation



La mise en service d'une ASI englobe le démarrage de l'équipement, le contrôle de ses fonctions par rapport aux spécifications de conception et la vérification de la compatibilité avec l'environnement de travail du client.

Socomec effectue la mise en service conformément à un processus de qualité visant à garantir la livraison d'un équipement sécurisé, fiable et opérationnel.

	PLACE YOUR CERTIFICATION HERE
CERTIFICATION OF "SAFE AND RELIABLE INSTALLATION"	
TECHNICAL SUPPORT	_____
HOT LINE	_____
CONTRACT No	_____
UPS TYPE	_____
POWER	_____
SERIAL NUMBER	_____
CONFIGURATION (single/parallel)	_____
COMMISSIONING DATE (UPS)	_____
COMMISSIONING DATE (Battery)	_____
VALIDITY OF THE CERTIFICATE (check renewal)	_____
<small>SOCOMECS (www.socomec.com) declares the system has been checked and certified for high quality and availability supply and reserves the right to limit the responsibility in case the start up and the maintenance is not performed by authorised personnel. The present certificate should be renewed on yearly basis.</small>	
<small>* Personnel is authorised only if trained by the manufacturer and enabled by a certificate released by the manufacturer. Only authorised personnel can insure Competence, Original spare parts, global diagnostic through appropriate tools, Update of the unit according to new releases.</small>	

Points clés

- > Inspection de l'environnement de travail
- > Contrôle de l'installation électrique (interrupteurs, câbles, disjoncteurs, etc.)
- > Contrôle interne et externe de l'ASI
- > Mise en marche et configuration du système
- > Essai de fonctionnement sur un système ASI unitaire et/ou parallèle
- > Test avec banc de charge (sur demande)

Avantages

- > Conformité avec les diverses normes relatives aux installations
- > Complète le test de réception en usine
- > Traçabilité de la mise en service
- > Certificat de conformité



Prix préférentiel contrat

Prix préférentiel du contrat de maintenance s'il est signé dans les six mois suivant la mise en service