



Certificate of Compliance

Certificate: 2186005 (112964_0_000)

Master Contract: 189705

Project: 70055890

Date Issued: 2016-01-18

Issued to: **Socomec S.A.**
rue de Westhouse 1
BP 10
Benfeld Cedex, 67235
FRANCE

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Patrick Quinty*
Patrick Quinty

PRODUCTS

CLASS - C321105 - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers - Manual

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report.

Part A:

Manual motor controller (MMC), SIRCO series 22 followed by 00 or 05 followed by 3 followed by 00 followed by 0, 1, 2, 3, 4, 6 or 8. Size M1 rated: 16 to 40A max. at 600Vac max., 3 phases; 25Hp max. at 600Vac 3 phases. Size M2 rated: 63 to 80A at 600Vac max, 3phases; 40HP max. at 600Vac, 3phases. Short circuit rating: 65kA max. at 600Vac max.

Manual motor controller (MMC), SIRCO is associated pole additional neutral or ground to the cat No. 22 followed by 00 followed by 55 or 75 followed by 00 0, 01, 02, 03, 04, 06 or 08.

Part B:

Manual Motor Controller Auxiliary Contacts Accessories, open type, series 22990001 and 22990011 for use in SIRCO Series 22 Manual Motor Controller. Electrical pilot duty A300.



Certificate: 2186005
Project: 70055890

Master Contract: 189705
Date Issued: 2016-01-18

Part C:

Manual Motor Controller Additional Pole, Single pole, open type, series 2200100 followed by 0, 1, 2, 3 or 4 for use in SIRCO M1 series 22 followed by 00 or 05 followed by 3 followed by 00 followed by 0, 1, 2, 3, 4. Open type Rating: 25HP max at 600Vac, general use: 40A at 600Vac; Enclosed type rating: 25HP max at 600Vac, general use: 30A at 600Vac.

Part D:

Polymeric Enclosed Manual Motor Controller, Three pole normally open (NO) with accessories, SIRCO M1 series 221 followed by 7 or 4 followed by 3 or 4, followed by 3, 4 or 5 followed by 0 or 1, followed by 0, 1, 2 or 3. Rating: 25HP max at 600Vac, general use: 30A at 600Vac. Short circuit rating: 65kA at 600Vac.

Manual motor controller (MMC), SIRCO series 221 followed by 4, followed by 55 or 75 followed by 10,11,12,13.

Part E:

Polymeric Enclosed Manual Motor Controller, Three pole normally open (NO) with accessories, SIRCO M2 series 222 followed by 7 or 4, followed by 3 or 4, followed by 3, 4 or 5 followed by 0 or 1 followed by 3, 4 or 6. rating: 40HP max at 600Vac, general use: 63A at 600Vac. Short circuit rating: 65kA at 600Vac.

Manual motor controller (MMC), SIRCO series 222 followed by 4, followed by 55 or 75 followed by 13, 14, 16.

Part F:

Manual Motor Controller Additional Pole ground or Neutral, Single pole, open type, series 22 followed by 0, 1, 2, 3 or 4 for use in SIRCO M1 & M2. Series 22 followed by 00, followed by 50 or 90, followed by 05 or 09.

APPLICABLE REQUIREMENTS

- | | | |
|-------------------------|---|---|
| CAN/CSA-C22.2 No.0.4-04 | - | Bonding of electrical equipment |
| CSA C22.2 No. 14-13 | - | Industrial Control Equipment |
| CSA-C22.2 No.94.2-15 | - | Enclosures for Electrical Equipment, Environmental Considerations. |
| CSA-C22.2 No.94.1-15 | - | Enclosures for Electrical Equipment, Non-Environmental Considerations |



Supplement to Certificate of Compliance

Certificate: 2186005 (112964_0_000)

Master Contract: 189705

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70055890	2016-01-18	Addition of neutral pole and protective ground module.
2731353	2014-06-04	Alternate material for handle axis Bergamid B700G30H and Increase of the torque capacity to 39.8 Lb.In (4.5Nm) for screw terminals of SIRCO M2.
2605735	2013-03-01	Modification of the auxiliary contact assembly method.
2504536	2012-03-14	Modification of the terminal clamp design.
2437433	2011-09-16	Correction of the SIRCO M2, series 222 ratings.
2297733	2010-09-14	Add series 221 and 222.
2186005	2009-08-14	New certification: Manual Motor controller (MMC) SIRCO series 22.