



Ref. Certif. No.

US-39455-M1-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Power measuring and monitoring device with integrated current sensors
Name and address of the applicant	SOCOMECSAS 1 RUE DE WESTHOUSE - B.P. 60010 BENFELD CEDEX 67235 FRANCE
Name and address of the manufacturer	SOCOMECSAS 1 RUE DE WESTHOUSE - B.P. 60010 BENFELD CEDEX 67235 FRANCE
Name and address of the factory	SOCOMECSAS 1 RUE DE WESTHOUSE - B.P. 60010 BENFELD CEDEX 67235 FRANCE <input checked="" type="checkbox"/> Additional Information on page 2
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Ib: 10A-I _{max} : 63A Operating Temperature: -10/55°C. 520V~ (Ph/Ph) - 300V~ (Ph/N) (see manual)
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	DIRIS Digiware S-Datacenter, DIRIS Digiware S-135, DIRIS Digiware S-130
Additional information (if necessary may also be reported on page 2)	The report was revised to include technical modifications. <input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61010-1:2010, IEC 61010-1:2010/AMD1:2016, IEC 61010-2-030:2017
As shown in the Test Report Ref. No. which forms part of this Certificate	E257746-D1003-2/A1/C0-CB issued on 2022-02-02

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/hcbnames

Date: 2022-02-02
Original Issue Date: 2022-01-20

Signature:
Jolanta M. Wroblewska



Ref. Certif. No.

US-39455-M1-UL

Factory(ies):

VIDEOTON EAS KFT
BERENYL UT 72-100
SZEKESFEHERVAR 8000 HUNGARY

Additionally evaluated to:

National Differences specified in the CB Test Report.

Summary of Modifications:

Modify the technical data of the interchangeable RJ45 connector in the table of critical components - see CB Test Report.

Additional information (if necessary)



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Signature:

Jolanta M. Wroblewska

Date: 2022-02-02

Original Issue Date: 2022-01-20