



Ref. Certif. No.

CN55683

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

SWITCH DISCONNECTOR

Name and address of the applicant

SOCOMECS.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOMECS.A.S  
1, Rue De Westhouse 67230 Benfeld Cedex France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp: 12kV;Ui: 1000V;Ith: 1800A;Ue:AC415V;Ie: 1800A;Utilization category:  
AC-22B;Icw: 50kA/1s;Icm(peak): 75kA;Number of poles:3P,4P;Rated  
frequency:50/60Hz

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

SIRCO 1800A;

Additional information (if necessary may also be reported on page 2)

IEC 60947-1:2020;IEC 60947-3:2020

A sample of the product was tested and found to be in conformity with

00901-CB2021CQC-099876

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: Dec.28,2021

Signature:

Xie ZhaoXu

CB 0066201