



Ref. Certif. No.

CN55586

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Switch-disconnector
Name and address of the applicant	SOCOMEK S.A.S 1, Rue De Westhouse 67230 Benfeld Cedex France
Name and address of the manufacturer	SOCOMEK S.A.S 1, Rue De Westhouse 67230 Benfeld Cedex France
Name and address of the factory	SOCOMEK S.A.S 1, Rue De Westhouse 67230 Benfeld Cedex France
<i>Note: When more than one factory, please report on page 2</i>	<input checked="" type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	See the Appendix
Trademark / Brand (if any)	SOCOMEK
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	INOSYS LBS 400A, INOSYS LBS 630A, INOSYS LBS 800A
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2020 in conjunction with IEC 60947-1:2020
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2021CQC-099628

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Dec.21,2021

Signature:

Xie ZhaoXu

CB 0066103

General product information:

INOSYS LBS 400A, INOSYS LBS 630A, INOSYS LBS 800A

Uimp: 12kV

Ui: 1500V

Ith: 400A, 630A, 800A

Ue: See table 1;

Ie: See table 1

Icw: 10kA/50ms

Icm: 10kA

Utilization category: DC-21B, DC-PV2 (suitable for 400-630A 2P appearance, 4P appearance 1500V)

Table 1

Ith (A)	400A	630A	800A
Ie (A) DC-21B 1000 VDC (2P/4P)	400A	630A	800A
Ie (A) DC-21B 1500 VDC (3P)	400A	630A	800A
Ie (A) DC-21B、DC-PV2 1500 VDC (2P、4P)	400A	630A	-

Additional information (if necessary)

Date: Dec.21,2021



Signature:





Xie ZhaoXu

Connection diagram for DC:

2P(400A/630A/800A)



2P(400A/630A)




Additional information (if necessary)

Date: Dec.21,2021


Signature: 
Xie ZhaoXu

3P


Configuration N°1



Configuration N°2



4P Configuration N°1 :2 回路 (2 circuits)



Page 3 of 4

Additional information (if necessary)

Date: Dec.21,2021

Signature:

Xie ZhaoXu

Type Explanation:

INOSYS LBS 800A

(1) (2) (3)

- (1) Type
- (2) Name of Product: Switch Disconnecter
- (3) Rating: 400、630A、800A

Page 4 of 4

Additional information (if necessary)

Date: Dec.21,2021

Signature:



Xie ZhaoXu

IEC**IECEE**

®

TM

Ref. Certif. No.

CN55586

Name of the factory	Address of the factory
1.SOCOMEK ELECTRIC (SHANGHAI) CO.,LTD	A30.NO.5399 Waiqingsong Road,Qingpu Industrial Park,Shanghai City
2.SOCIETE TIMELEC SARL	ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS, Tunisia

Additional information (if necessary)

Date: Dec.21,2021

Signature:



Xie ZhaoXu