



中国国家强制性产品认证证书

证书编号：2024010305641593

认证委托人名称及地址

法国溯高美电气公司

1, Rue De Westhouse 67230 Benfeld Cedex France

生产者名称及地址

法国溯高美电气公司

1, Rue De Westhouse 67230 Benfeld Cedex France

生产企业名称及地址

法国溯高美电气公司

1, Rue De Westhouse 67230 Benfeld Cedex France

产品名称和系列、型号、规格

转换开关电器

ATyS 2000A,ATyS d 2000A,ATyS t 2000A,ATyS g 2000A,ATyS p 2000A, ATyS A 2000A,ATyS C 2000A, ATyS 2500A,ATyS d 2500A,ATyS t 2500A,ATyS g 2500A,ATyS p 2500A,ATyS A 2500A,ATyS C 2500A, ATyS 3200A,ATyS d 3200A,ATyS t 3200A,ATyS g 3200A,ATyS p 3200A,ATyS A 3200A,ATyS C 3200A; 详见附页

产品标准和技术要求

GB/T14048.11-2024

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求,特发此证。

发证日期: 2025 年 06 月 24 日 有效期至: 2029 年 06 月 11 日

本证书为变更证书,证书首次颁发日期: 2024 年 06 月 12 日
证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号: 2024010305641593

证书附页: 第 1 页 共 1 页

ATyS 2000A,ATyS d 2000A,ATyS t 2000A,ATyS g 2000A,ATyS p 2000A,
ATyS A 2000A,ATyS C 2000A,ATyS 2500A,ATyS d 2500A,ATyS t 2500A,
ATyS g 2500A,ATyS p 2500A,ATyS A 2500A,ATyS C 2500A,ATyS 3200A,
ATyS d 3200A,ATyS t 3200A,ATyS g 3200A,ATyS p 3200A,ATyS A 3200A,
ATyS C 3200A

Ui:1000V(主回路),300V(控制回路);

Uimp:12kV(主回路),4kV(控制回路);

Ue:AC415V;

ATyS 2000A,ATyS d 2000A,ATyS t 2000A,ATyS g 2000A,ATyS p 2000A,
ATyS A 2000A,ATyS C 2000A:

Ith:2000A;

Ie:2000A(AC-32B),1600A(AC-33iB),1250A(AC-33B);

ATyS 2500A,ATyS d 2500A,ATyS t 2500A,ATyS g 2500A,ATyS p 2500A,
ATyS A 2500A,ATyS C 2500A:

Ith:2500A;

Ie:2500A(AC-31B),2000A(AC-32B,AC-33iB),1250A(AC-33B);

ATyS 3200A,ATyS d 3200A,ATyS t 3200A,ATyS g 3200A,ATyS p 3200A,
ATyS A 3200A,ATyS C 3200A:

Ith:3200A;

Ie:3200A(AC-31B);

Icw:50kA/60ms;Icm(峰值):105kA;

电器级别:PC 级;

ATyS,ATyS d,ATyS t,ATyS g,ATyS p,ATyS C(配控制器 ATyS C35):50/60Hz;

ATyS A,ATyS C(配控制器 ATyS C25),ATyS t:50Hz 或 60Hz;

转换方式:ATSE,RTSE;

极数:3P,4P.

本页为证书附页,应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010305641593

NAME AND ADDRESS OF THE APPLICANT

SOCOMEK S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND ADDRESS OF THE MANUFACTURER

SOCOMEK S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND LOCATION OF THE FACTORY

SOCOMEK S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

PRODUCT NAME,MODEL AND SPECIFICATION

Transfer Switching Equipment

ATyS 2000A,ATyS d 2000A,ATyS t 2000A,ATyS g 2000A,ATyS p 2000A, ATyS A 2000A,ATyS C 2000A, ATyS
2500A,ATyS d 2500A,ATyS t 2500A,ATyS g 2500A,ATyS p 2500A,ATyS A 2500A,ATyS C 2500A, ATyS 3200A,ATyS d
3200A,ATyS t 3200A,ATyS g 3200A,ATyS p 3200A,ATyS A 3200A,ATyS C 3200A ; See the appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.11-2024

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jun.24,2025

Valid until: Jun.11,2029

Date of original issued: Jun.12,2024

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010305641593

Appendix: Page 1 of 1

ATyS 2000A,ATyS d 2000A,ATyS t 2000A,ATyS g 2000A,ATyS p 2000A, ATyS A
2000A,ATyS C 2000A,ATyS 2500A,ATyS d 2500A,ATyS t 2500A,ATyS g
2500A,ATyS p 2500A,ATyS A 2500A,ATyS C 2500A,ATyS 3200A,ATyS d
3200A,ATyS t 3200A,ATyS g 3200A,ATyS p 3200A,ATyS A 3200A,ATyS C 3200A;
Ui: 1000V(main circuit), 300V(controller);
Uimp: 12kV(main circuit), 4kV(controller);
Ue: AC415V;
ATyS 2000A,ATyS d 2000A,ATyS t 2000A,ATyS g 2000A,ATyS p 2000A, ATyS A
2000A,ATyS C 2000A:
Ith: 2000A;
Ie: 2000A(AC-32B), 1600A(AC-33iB), 1250A(AC-33B);
ATyS 2500A,ATyS d 2500A,ATyS t 2500A,ATyS g 2500A,ATyS p 2500A,ATyS A
2500A,ATyS C 2500A:
Ith: 2500A;
Ie: 2500A(AC-31B), 2000A(AC-32B, AC-33iB), 1250A(AC-33B);
ATyS 3200A,ATyS d 3200A,ATyS t 3200A,ATyS g 3200A,ATyS p 3200A,ATyS A
3200A,ATyS C 3200A:
Ith: 3200A;
Ie: 3200A(AC-31B);
Icw:50kA/60ms, Icm(peak value): 105kA;
ATSE Class:PC;
ATyS,ATyS d,ATyS t,ATyS g,ATyS p,ATyS C(ATyS C35):50/60Hz;
ATyS A,ATyS C(ATyS C25),ATyS t:50Hz 或 60Hz;
Transfer Mode:ATSE,RTSE;
Poles:3P,4P.

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.