



Ref. Certif. No.

CN64958

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Transfer Switching Equipment

Name and address of the applicant

SOCOMECA S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECA S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Zhejiang Socomec Co.,Ltd.

Note: When more than one factory, please report on page 2

Heshenqiao Industrial Zone Puqi Yueqing Zhejiang P.R.China
(Zhejiang KEDU Electric Manufacture CO.,LTD.)

Ratings and principal characteristics

Uimp:6kV(main circuits and control circuits); Ui:800V(main circuits),450V(control circuits); Ith: 25A,32A,40A,63A; Ue:AC415V; Ie:25A,32A,40A,63A; Utilization category:AC-33B; Icm (peak): 7.65 kA; Icw:5kA/30ms; Iq:50kA; Class of equipment: PC; Method of controlling: ATSE,MTSE; Number of poles: 4P

Trademark (if any)

SOCOMECA

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

ATyS a M 25A, ATyS a M 32A, ATyS a M 40A, ATyS a M 63A;

Additional information (if necessary may also be reported on page 2)

IEC 60947-6-1:2021;IEC 60947-1:2020

A sample of the product was tested and found to be in conformity with

00901-CB2023CQC-112360

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Feb.21,2024

Signature: 谢肇煦

Xie ZhaoXu

