



Ref. Certif. No.

CN65939

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

Transfer Switching Equipment

Name and address of the applicant

SOCOMECA S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECA S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCIETE TIMELEC SARL

ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA  
NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS,  
Tunisia

Note: When more than one factory, please report on page 2

Uimp:8kV; Ui:800V; Ith:125A,160A,200A; Ue:AC415V;  
Ie:125A(SIRCOVER AC 125A),160A(SIRCOVER AC  
160A),200A(SIRCOVER AC 200A); Utilization category:AC-31B;  
Iq:100kA(SIRCOVER AC 125A, SIRCOVER AC 160A);  
50kA(SIRCOVER AC 200A); Class of equipment: PC; Method of  
controlling: MTSE; Number of poles: 3P,4P

Trademark (if any)

SOCOMECA

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SIRCOVER AC 125A, SIRCOVER AC 160A, SIRCOVER AC 200A;

Additional information (if necessary may also be  
reported on page 2)

IEC 60947-6-1:2021;IEC 60947-1:2020

A sample of the product was tested and found  
to be in conformity with

00901-CB2024CQC-113620

As shown in the Test Report Ref. No. which  
forms part of this Certificate

**CHINA QUALITY CERTIFICATION CENTRE CO., LTD.**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: May.29,2024

Signature: 谢肇煦  
Xie ZhaoXu

