

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Transfer Switching Equipment

Name and address of the applicant

SOCOMECA S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECA S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOMECA S.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:12kV; Ui:1000V; Ith:1600A;Ue:AC415V;
Ie:1600A(AC-31B),1250A(AC-32B); Utilization category:
AC-31B,AC-32B; Icm:67.2kA; Icw:32kA/60ms; Class of
equipment: PC; Method of controlling: MTSE; Number of
poles: 3P,4P

SOCOMECA

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SIRCOVER AC1600A;

A sample of the product was tested and found
to be in conformity with

IEC 60947-6-1:2021;IEC 60947-1:2020

00901-CB2024CQC-113616

As shown in the Test Report Ref. No. which
forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.


Section 9, No. 188 Nanshuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.10,2024

Signature:


Xie ZhaoXu