

IEC**IECEE**

Ref. Certif. No.

CN76672

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Transfer Switching Equipment

Name and address of the applicant

SOCOMECS.A.S
1, RUE DE WESTHOUSE 67230 BENFELD CEDEX FRANCE

Name and address of the manufacturer

SOCOMECS.A.S
1, RUE DE WESTHOUSE 67230 BENFELD CEDEX FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

SOCOMECELECTRIC (SHANGHAI) CO.,LTD
Building A30, No.5399 Waiqingsong Road Qing Pu.Shanghai
P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

ATyS□□ (ATyS dM 40A,ATyS dM 63A,ATyS dM 80A,ATyS dM 100A,ATyS dM 125A,ATyS dM 160A,ATyS gM 20A,ATyS gM 32A,ATyS gM 40A, ATyS gM 63A,ATyS gM 80A,ATyS gM 100A,ATyS gM 125A,ATyS gM 160A,ATyS tM 20A,ATyS tM 32A,ATyS tM 40A,ATyS tM 63A, ATyS tM 80A,ATyS tM 100A,ATyS tM 125A,ATyS tM 160A,ATyS cM 40A,ATyS cM 63A,ATyS cM 80A,ATyS cM 100A,ATyS cM 125A, ATyS cM 160A,ATyS pM 40A,ATyS pM 63A,ATyS pM 80A,ATyS pM 100A,ATyS pM 125A,ATyS pM 160A,ATyS aM 20A,ATyS aM 32A, ATyS aM 40A,ATyS aM 63A,ATyS aM 80A,ATyS aM 100A,ATyS aM 125A,ATyS aM 160A)

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020; IEC 60947-6-1:2021

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2025CQC-122445

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.Section 9, No. 188, Nansihuan Xilu, Fengtai District, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Apr.21,2026

Signature:

Liu Jiang

ATyS□□

(ATyS dM 40A,ATyS dM 63A,ATyS dM 80A,ATyS dM 100A,ATyS dM 125A,ATyS dM 160A,ATyS gM 20A,ATyS gM 32A,ATyS gM 40A,

ATyS gM 63A,ATyS gM 80A,ATyS gM 100A,ATyS gM 125A,ATyS gM 160A,ATyS tM 20A,ATyS tM 32A,ATyS tM 40A,ATyS tM 63A,

ATyS tM 80A,ATyS tM 100A,ATyS tM 125A,ATyS tM 160A,ATyS cM 40A,ATyS cM 63A,ATyS cM 80A,ATyS cM 100A,ATyS cM 125A,

ATyS cM 160A,ATyS pM 40A,ATyS pM 63A,ATyS pM 80A,ATyS pM 100A,ATyS pM 125A,ATyS pM 160A,ATyS aM 20A,ATyS aM 32A,

ATyS aM 40A,ATyS aM 63A,ATyS aM 80A,ATyS aM 100A,ATyS aM 125A,ATyS aM 160A)

Ui:800V(main circuit);300V(control circuit);

Uimp:6kV(main circuit);4kV(ATyS dM,control circuit);

2.5kV(ATyS pM,ATyS gM,ATyS tM,ATyS cM,ATyS aM,control circuit);

Ue:AC415V;lth:160A;

ATyS dM,ATyS pM,ATyS cM:

Ie:AC-32B:40A,63A,80A,100A,125A,160A;

AC-33B:40A,63A,80A,100A,125A;

AC-32A:40A,63A,80A,100A;

ATyS gM,ATyS tM:

Ie:AC-32B:20A,32A,40A,63A,80A,100A,125A,160A;

AC-33B:20A,32A,40A,63A,80A,100A,125A;

AC-32A:20A,32A,40A,63A,80A,100A;

ATyS aM:

Ie:AC-32B:20A,32A,40A,63A,80A,100A,125A,160A;

AC-33B:20A,32A,40A,63A,80A,100A,125A;

AC-32A:20A,32A,40A,63A,80A,100A;

Utilization category:AC-32A,AC-32B,AC-33B;

Iq:40kA(Ie:160A),50kA(Ie:20A,32A,40A,63A,80A,100A,125A);

Class of equipment:PC;

ATyS dM,ATyS pM,ATyS cM,ATyS gM:50/60Hz;ATyS aM,ATyS tM:50Hz or 60Hz;

ATSE(ATyS pM,ATyS cM,ATyS gM,ATyS tM,ATyS aM);RTSE(ATyS dM);

Page 1 of 2

Additional information (if necessary)

Date:

Apr.21,2026

Signature:



Liu Jiang

IEC

IECEE

®

™

Ref. Certif. No.

CN76672

4P.

Page 2 of 2

Additional information (if necessary)

Date:

Apr.21,2026

Signature:



Liu Jiang